

Test Verification of Conformity

Verification Number: 230100362HAN-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant  mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	SHAOXING SHANGYU NORTH ELECTRON MANUFACTURE CO., LTD YUEXIE ROAD, SHANGYU DISTRICT, SHAOXING CITY, ZHEJIANG PROVINCE, P.R.CHINA.
Product Description:	Ice maker
Ratings & Principle Characteristics:	220-240V, 50Hz, 125W, 0,8A, R600a/30g, Climate: N/SN, Class I, insulation blowing gas: C ₅ H ₁₀
Models/Type References:	CB22C
Brand Name:	/
Relevant Standards/Directives:	EN IEC 55014-1:2021 EN IEC 55014-2:2021 EN IEC 61000-3-2:2019+A1:2021 EN 61000-3-3:2013+A1:2019+A2:2021 the EMC directive(2014/30/EU)
Verification Issuing Office Name & Address:	Intertek Testing Services Zhejiang Ltd. Building No. 2, Juanhu Science and Technology Innovation Park, No. 500 Shuiyueting East Road, Haining City, Zhejiang Province, China
Date of Tests:	February 8, 2023 ~ July 6, 2023
Test Report Number(s):	230100362HAN-001


Signature

Name: Leo Ye

Position: Manager

Date: November 27, 2023

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.